S/GRA/SVTA4690/C/10/07/2002 -

Page 1/6 GB

S

a

DIGITAL THREE PHASE ANGLE CONTROLLER

- Allows to set the voltage applied to different sort of loads with 3 wires, 4 wires or inside the delta wiring:
 - ▶ Resistive (Bulbs, UV and IR lamps, ovens, ...),
 - ▶ Inductive (inductors, transformers, ...),
 - ▶ Motor (motorfan speed control (60 to 100% from the nominal speed),
 - ▶ Rectified (power supplies, ...).


celduc


- Small housing, easy and ready to use.
- Large mains frequency and voltage range.
- ▶ Fully optoisolated full cycle three phase phase angle controller (balanced currents, less harmonics, ...)
- > Dynamic control voltage range according to the power factor of the load.
- ▶ Softstart and softstop functions (increase lifetime expectancy of the load).
- ▶ Adjustable filter regarding fast input voltage changes (ramps).
- Motor softstarting functions to control its speed within the stable area.
- ▶ Input-output transfert characteristic linearization function (resistive load).
- ▶ Diagnostic features : Status given on LED and AC/DC switches.



SVTA4690

Proportionnal analog voltage control input 0-10V 200->480VAC 50A(125A) AC-51





PHASE ANGLE CONTROL DESCRIPTION Fig. 3 Fig. 4 **INTERNAL DIAGRAM** 1L1 3L2 5L3Load Resistive Load Supply Up/Lin LED 6 Urg. K tr Stop +5 Firing time delay 3 m ₩₹ Inductive Load Diag. 2 Element 12 2T1 4T2 6T3 Θ Firin time delay Ramp Initial Options time(s) value Proud to serve you Data given at Tambient=40°C and subject to modification without previous notice

r

e

Page 2/6 GB

SETTINGS

	Label	"Ramp Time (s)"	"Initial Value"	"Soft Stop"	"Comp"	"Load"	"Ntrl"	"Curve"
SN	Description	Ramp Time(s) $0.25 \\ 0 \\ 0.4 \\ 32 \\ 16 \\ 16 \\ 16 \\ 16 \\ 16 \\ 16 \\ 16 \\ 1$	Initial Value 0.2 0 0 0,0 0.5 0.6 0.7 0.7 0.7					
ID OPTIONS	Function	Ramp up time (Softstart and smooth transients)	Initial load voltage (footstep)	Ramp down time	Allows to adapt the control signal range whatever the power factor of the load	Ask the unit to make a softstart up to the max. before analog control.	Tells the unit the load star point is connected to the mains neutral	Tells the unit what kind of in- out response to use (angle or RMS voltage linearity)
AN	Setting		Vi=0 to 100 %	0 x ts = 0,5 x ts =	On (Up)	On (Up)	On (Up)	On (Up)
SETTINGS AND	possibilities White squares = buttons Example :	Ts= 0 to 64s			Inductive load	Motor	Star wiring with neutral (4 wires)	RMS voltage control
SE	= all switches down (OFF) (factory setting)	$1 \mathrm{s} = 0$ to $64 \mathrm{s}$	VI-0 to 100 %	ts =	ts = Off (Down) Off (Down) Off (Do	Off (Down)	Off (Down)	
				2 x ts =	Resistive load	Other loads than motors	Delta or star without neutral	Phase angle control

--- celduc®

INPUT CHARACTERISTICS

	CHARACTERISTIC				INFO.
	Labels		"0-10V"	"Urg. Stop"	
	Function		Analog control input	Stop the thyristor controls	
Ш.	Control type		DC control voltage	Opening the connection between 5 & 6	
CU	Terminals		4 & 6	5 & 6	
IR	Control voltage range	Uc	0-10VDC	-	
INPUT CIRCUIT	Release and control threshold voltage	Ucsmin	0.3VDC	-	
IdN	Full power threshold control voltage	Ucsmax	9.7VDC	-	
Ι	Max. input voltage	Ucmax	30VDC	6VDC	
	Max. reverse voltage	-Ucmax	30VDC	6VDC	
	Release voltage	\mathbf{Ut}		>1,5V	
	Input impedance	Re	$100 \mathrm{k}\Omega$	-	See fig. 5
	Current to switch	Ict	-	20mADC	Ict=f(Ut)
	Labels		"Diag. "	"Pwr"	
	Terminals		1 & 2	2 & 3	
	Function		Indicates a problem detected in the circuit configuration	Indicates the load is supplied	
\mathbf{TS}	Nominal operating voltage Usan 24VAC/DC		C/DC		
ΡU	Operating voltage range				
Πſ	Max. peak voltage	Usap	60)V	
10	Overvoltage protection		Built-in 25V s		
US	Minimum load current	Ipw/Ipb	0A		
₹T	Maximum load current Ipw/		1A A	See fig. 6	
STATUS OUTPUTS	Maximum overload current	Ipw/Ipb	2.4A A	@100ms 10% of the cycle	
	On and off state switch resistance	Ron / Roff	$500 { m m} \Omega$ /	/ 100ΜΩ	See fig. 6
	On and off time delay	Ton / Toff	0.5ms		

Page 3/6 GB

OUTPUT CHARACTERISTICS

CHARACTERISTIC	LABEL		VALUE		INFO.
Mains voltage range	Ue	200 -> 480VAC			
Non-repetitive peak voltage	Uep	1200V			
Overvoltage protection	VDR	Built			
Maximum nominal currents Nota : Wire cross section limited to 10mm ² (50A) by the terminals	Ie	Resistive Ithmax AC51 50A (125A)	Motor _{Iemax} AC53a 30A	Motor Ie AC53a 22A	See fig. 7 for limits Values with
Maximum line currents in delta wiring	ILine	87A (216A)	38A	- heatsink Delta wiring : See installation manual	
Max motor power	Pe	15kW	@400VAC star conn	ection	
Non-repetitive peak overload current (1 cycle of 10ms)	ITSM		2000A		See fig. 8
Melting limit for choosing the protective fuses	$\mathbf{I}^{2}\mathbf{t}$		20000A ² s		@10ms
Minimum load current	Iemin		100mA		
Maximum leakage current	Ielk		7mA		@400VAC 50Hz
Power factor	Pf		0->1		
Mains frequency range	\mathbf{F}		40->65Hz		
Max. off-state voltage rise	dv/dt		500V/µs		
Protection against fast voltage transients			Buit-in RC network		
Max. current rise	di/dt		50A/µs		
On-state voltage drop	Ud		@Ith		
Resistive part of the voltage drop	rt		@125°C		
Potential part of the voltage drop	Vto		@125°C		
Maximum junction temperature	Tjmax				
Junction/case thermal resistance per power element	Rthjc		0.25K/W		Total = 3 power elements
Case heatsink thermal resistance	Rthcs		-		
Product only thermal resistance vertically mounted	Rthra		4K/W		@∆Tra=60°C
Heatsink thermal time constant	Tthra		15min		@∆Tra=60°C
Inputs/power ouputs insulation voltage	Uimp		4kV		
Input/status outputs insulation voltage	Uied		$2.5 \mathrm{kV}$		
Inputs/case insulation voltage	Uimp	4kV			
Status outputs/case insulation voltage	Uimp				
Isolation resistance	Rio	1GΩ			
Isolation capacitance	Cio	<8pF			
Storage ambient temperature	Tstg	-40->+100°C			
Operating ambient temperature	Tamb	-40->+90°C			See fig. 7
Max. heatsink temperature	Тс				




Page 4/6 GB

ΓX	CHARACTERISTIC	LABEL	VALUE		INFO.
AL PP	Terminals		3L2 & 5L3		
RN. SU	Mains voltage range	Ue	200->480VAC		
NTERNAL VER SUPP	Consumption	Is	1mA t	ypical	
IN] WE	Mains frequency range	F	40-65Hz		
[] DO	Turn-on time	tm	100		
				GENERAL INFOR	MATION
	Connections		Power	Input terminal block	
$s_{\rm C}$	Screwdriver advised		Posidriv 2 or 0.8 x 5.5mm	0.8 x 2mm	
NE NE	Min and max tightening torque		1.8->3N.m		
CONNEC- TIONS	Number and cross section of the wires		$\begin{array}{c} 2 \text{ x } 1.5\text{->}6\text{mm}^2\\ \text{(10mm^2 without ferrule)} \end{array} \qquad 1 \text{ x } 2.5\text{mm}^2 \end{array}$		
	Screwdriver for settings		0.8 x		
	Housing		UL9	94V0	
MISC.	Mounting		Screwed		
SIIV	Noise level		Low audible	e vibrations	
	Weight		50	0g	
				ST A	VDARDS
				SIA	VDANDS
	Standards		EN60947-4-2 & EN60947-4-3		
AL	Protection level		IP2	2L0	
GENERAL	Protection against direct touch		Accordin to V.D.		
BN			Back hand and		
5	CE marking			es	
	UL, cULUS and VDE approvals		Pen	ding	
	TYPE OF TEST	STANDARD	LEV	/EL	EFFECT
ΤΥ	E.S.D. (Electrostatic discharges)	EN61000-4-2	8kV 4kV (t		No effect
I.C.	Radiated electromagnetic fields	EN61000-4-3	101	7/m	No effect
E.M.C. AMUNI	Fast transients bursts	EN61000-4-4	2kV direct coupling on the power side 2kV coupling by clamp on the input side		No effect
	Electric chocks	EN61000-4-5	1kV direct coupling different 2kV direct coupling commo	No effect	
	Voltage drop	EN61000-4-11	-	-	
E.M.C. EMISSION	Radiated and conducted disturbances	NFEN55011	solid state relays depend configuration. The test method recommende and concerning electromagne results far from reality, we de in order to adapt their filterin	d by the European standards etic compatibility leading to ecided to advise our customer	


INTERNAL POWER SUPPLY

Page 5/6 GB





Page 6/6 GB





. celduc



www.celduc.com

Rue Ampère B.P. 4 42290 SORBIERS - France Phone : 33 (0) 4 77 53 90 21 Fax : 33 (0) 4 77 53 85 51 Email : celduc-relais@celduc.com

S

					SVTA	-SWTA DIAGNO	STIC			
						NORMAL OPERATION				
LED DISPLAY OUTPUTS			PUTS	LOAD		COM	IFNTS			
Supply	Line Up	Load Down	Pwr	Diag.	LOAD	COMMENTS				
ANALOG INPUT VOLTAGE BELOW THE MINIMUM CONTROL VOLTAGE THRESHOLD										
	$\bigcirc \bigcirc $	$\bigcirc \bigcirc $			OFF	LEDs blinking sequend Load connected Analog input voltage b	Phase presence = OK ; Phase voltage = OK ; Phase frequency = OK LEDs blinking sequence indicates mains phase rotation is direct			
0000	0000	0000		_	OFF	LEDs blinking sequend Load connected Analog input voltage b	Phase presence = OK ; Phase voltage = OK ; Phase frequency = OK LEDs blinking sequence indicates mains phase rotation is reverse			
		ANAL	OG INP	UT VOL	TAGE ABO	VE THE MINIMUM CON	NTROL VOLTA	GE THRES	HOLD	
\bigcirc	\bigcirc	0			ON	(Time ramp (s)) is incr	easing.		tage ramp set by the user	
\bigcirc	\bigcirc	0			ON	Indicates the voltage a	t the analog inpu		ne maximum full power 9V (0-5V / potentiometer))	
\bigcirc	\bigcirc	\bigcirc		$\left \right $	ON	Indicates the voltage a (soft-stop) is decreasing		ut or the vol	tage ramp set by the user	
\bigcirc	0	0			ON	Stable analog input vo NOTA : A fast UP/DOV	ltage or voltage i			
		•			A	BNORMAL OPERATION				
LE	D DISPI	AY	OUT	PUTS	TOTO					
Supply	Line Up	Load Down	Pwr	Diag.	LOAD	POSSIBLE (CAUSE		SOLUTION	
			W	HATEVI	ER IS THE	VOLTAGE VALUE AT T	HE ANALOG II	NPUT		
0	0	0			OFF	Mains is missing or it the motor side (2T1, 4 device, instead of the r 3L2, 5L	T2, 6T3) of the nains side (1L1,	Check	s the power side wiring	
	0				OFF	Mains voltage	too low	-	se to phase voltage between 3L2 and 5L3	
0		0			OFF	1 or 2 phase(s) Mains frequency o Too many distu	out of range,		Check the phases	
				4	OFF	Microcontroller malf many problems at t			t the device from the mains hile and check the wiring	
0			-/-	-	OFF	Load connection Shorted thyri		the power	d connections and measure element resistance (should several 100kOhms)	
\bigcirc		0	-/	-	OFF	A problem on the mai phase missing) and m analog input voltag	ow it is OK but	Remove th	e analog input voltage for a while	
\bigcirc					OFF	temporary disconnect is OK but analog in	A problem on the load occurred (e.g. temporary disconnection) and now it is OK but analog input voltage is present		e analog input voltage for a while	
	\bigcirc	\bigcirc	/	/	OFF	Factory diag	nostic		Consult us	
		ANAL	OG INP	UT VOL	TAGE ABO	VE THE MINIMUM CON	NTROL VOLTA	GE THRES	SHOLD	
					OFF		Power elements can not turn on		nnection between 5 and 6 of ol terminal block. Check the rent is above the minimum specified	
0		0			ON	1 or 2 phase(s) missing, Mains frequency out of range, Too many disturbances		Check the phases		
LEGENDE										
	\bigcirc			\bigcirc						
OFF			GREEN		N	RED	BLINK OFF/GR		BLINKING OFF/RED	
L									•	

IMPORTANT INFORMATION CONCERNING THE DIAGNOSTIC

The device makes a complete diagnostic (mains, load and itself) as soon as the mains voltage is sufficient

2-The device checks only the presence of phases when the analog input voltage is above the minimum control threshold, during the ramps (softstart and softstop) and when it is full on (the power elements are tested only when analog control voltage is below the minimum control voltage threshold). 3-

- The control overrides the diagnostic.
 - If a problem occurs during the control period, the device will try to go on driving the load according the analog
 - input voltage. If the problem goes on, it will be if possible indicated to the user according the diagnostic table.

If a problem occurs during the softstopping period, the device will stop immediately in order to reach the off _ state diagnostic period.

PRELIMINARY 22/01/04

1-